

Ref. SEC17-125/AP/001223

Date: 01 November 2021

To : Al Firdous Aluminum & Glass Cont.
P.O. Box 86282, Al Ain, UAE
Tel.: 03 782 4152; Fax: 03 782 4153

Attention : Mr. Jacob Koshy – Managing Partner

Project : MOI-14/1-SPE/GEN001

Subject : RE: Material Submittal - Bullet Proof Glass & Frame

Dear Sir,

Reference to your letter dated 10/10/2021. regarding the above-mentioned material submittal, we approved as per comments below:

1. **Glass-LBR6-NS-41.22 mm** – Test Certificate and Warranty Certificate must be provided from the Manufacturer.
2. **Frame** – Metal frame need to be approved by the Designer/Bullet proof Manufacturer.
 - SS finish should be brush finish.
3. **Drawings** - Find comments on the attached drawings.

This is for your information and action.

Yours Sincerely,

For and on Behalf of

Specialist Engineering Consultancy

Engr. Ajith Prakash
Construction Manager

Attached: material photo & drawing with comments

I-25007